



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx EPS 19.0039X	Page 1 of 5	Certificate history:
Status:	Current	Issue No: 1	Issue 0 (2019-06-06)
Date of Issue:	2025-06-04		
Applicant:	Schischek GmbH Mühlsteig 45, Gewerbegebiet Süd 5 90579 Langenzenn Germany		
Equipment:	Actuator Type ExRun		
Optional accessory:			
Type of Protection:	protection by flameproof enclosures "db", increased safety "eb", protection by intrinsic safety "ib", dust ignition protection by enclosure "tb"		
Marking:	Ex db eb [ib Gb] IIC T6, T5, T4 Gb Ex tb [ib Db] IIIC T80°C, T95°C, T130°C Db		

Approved for issue on behalf of the IECEx
Certification Body:

Position:

Signature:
(for printed version)

Date:
(for printed version)



1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Bureau Veritas Consumer Products Services Germany GmbH
Businesspark A96
86842 Türkheim
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX EPS 19.0039X**

Page 2 of 5

Date of issue: 2025-06-04

Issue No: 1

Manufacturer: **Schischek GmbH**
Mühlsteig 45, Gewerbegebiet Süd 5
90579 Langenzenn
Germany

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-1:2014 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

DE/EPS/ExTR19.0038/00

DE/EPS/ExTR19.0038/01

Quality Assessment Report:

DE/BVS/QAR07.0009/18



IECEX Certificate of Conformity

Certificate No.: **IECEX EPS 19.0039X**

Page 3 of 5

Date of issue: 2025-06-04

Issue No: 1

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The actuator, type ExRun-*** consists of a flameproof enclosure with actuator shafts that accommodate electromechanical components. The internal portion is temperature controlled. The flameproof enclosure is mounted in a protective housing together with additional mechanical components. The gears and mechanical actuators mounted in the protective housing do not form part of this type approval.

Connection is by means of a increased safety junction box

For coated housings with a layer thickness of more than 0.2 mm, Ex-marking IIB can be used.

Electrical data:

Power supply: terminals 1-5 (X1, XA)

Nominal voltage U_o/U _____ up to	24 – 240 V
Rated voltage _____ max.	240 V
Rated current _____ max.	2,5 A

Option –S terminals 1-6 (XB)

Nominal voltage U_o/U _____ up to	24- 230 V
Rated voltage _____ max.	240 V
Rated current _____ max.	5,0 A

Option –Y terminals 1-6 (X2, XB)

Nominal voltage U_o/U _____ up to	24 V
Rated voltage _____ max.	24 V
Rated current _____ max.	30 mA

Rated values are maximum values, the actual electrical values are determined by mounted electrical apparatus. Within these limiting values complying with the appropriate standards, the manufacturer specifies the final limiting values dependent on power supply specifications, operating mode, utilization category, etc. Any additional technical features are specified in the test documents and the operating manual.

Ambient temperature	T6	-40 °C up to +40 °C
	T5	-40 °C up to +50 °C
	T4	-40 °C up to +60 °C

SPECIFIC CONDITIONS OF USE: YES as shown below:

Only for coated enclosure - Warning of electrostatic discharge, see operating instructions.



IECEX Certificate of Conformity

Certificate No.: **IECEX EPS 19.0039X**

Page 4 of 5

Date of issue: 2025-06-04

Issue No: 1

Equipment (continued):

Intrinsic safe circuits

RS232, terminals 1-6 (EEXi output, SV101)

U_o _____

5,88 V

I_o _____

119 mA

P_o _____

0,7 W

Linear circuit

Li negligible

Ci negligible

Maximum of external lumped capacitance and inductance:

	Ex ib IIC	IIB	IIA
Lo	2 mH	2 mH	2 mH
Co	43 μ F	1000 μ F	1000 μ F



IECEX Certificate of Conformity

Certificate No.: **IECEX EPS 19.0039X**

Page 5 of 5

Date of issue: 2025-06-04

Issue No: 1

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

New special condition of use (Electrostatic charges on external non-metallic materials)