



Certificate of Compliance

Certificate: 70005775

Master Contract: 236433

Project: 80197860

Date Issued: May 19, 2025

Issued to: Rotork UK Ltd
9 Brown Lane West,
Holbeck, Leeds,
LS12 6BH
UNITED KINGDOM

Attention: John Templeman

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by:

Stewart C. Finch

PRODUCTS

CLASS 2258 02 – Process Control Equipment - For Hazardous Locations

Rotork SI3 and SI4, Skilmatic Range of Electro-Hydraulic Control Modules; Input rated - 24Vdc, max. 0.29 kW; 110/120Vac 60Hz 1Ø, max. 1.34 kVA or 230Vac 60Hz 1Ø, max. 1.25 kVA; 230Vac 50Hz 1Ø, max. 0.97 kVA; 380-440Vac, 50/60Hz 3Ø, max. 1.66 kVA; 480-575Vac, 60Hz 3Ø, max. 1.66 kVA (with an optional Power Module) or 5.5 kW (with a suitably approved third party motor & hydraulic pump)

Ex db eb* IIC T4 Gb IP 66/68**

Ex db eb* IIB T4 Gb IP 66/68**

T amb -40°C* ≤ T_a ≤ +70°C*****

Type 4, Type 6

* “eb” marking only present on versions with increased safety terminal enclosure

** Only IP64 is endorsed by CSA, IP 66/68 testing in accordance with ANSI/IEC 60529:04 (R2011).

*** minimum and maximum values, all values within this range may be quoted within the following limitations:

down to -40°C, up to 70°C (Configuration 1 – IIB & IIC)

down to -40°C, up to 70°C (Configuration 2 – IIB)

down to -20°C, up to 70°C (Configuration 2 – IIC)

Explosionproof for Class I, Division. 1, Groups B, C, D; Temperature Code T4; T amb -40°C ≤ T_a ≤ +70°C



Certificate: 70005775

Master Contract: 236433

Project: 80197860

Date Issued: May 19, 2025

Notes:

1. The above model is permanently connected, Equipment Class I, Pollution Degree 2, Overvoltage Category II.
2. Mode of operation: Isolating (on/off) or Intermittent/duty cycle 300 starts 75% maximum duty up to 40°C; and 300 starts 40% maximum duty from 41°C to 70°C.
3. Environmental Conditions: Normal: 2000 m max, 80% to temperatures up to 31 °C decreasing linearly to 50% rH at 40 °C; or Extended/as specified by manufacturer.

CLASS 2258 82 – Process Control Equipment - For Hazardous Locations – Certified to US Standards

Rotork SI3 and SI4, Skilmatic Range of Electro-Hydraulic Control Modules; Input rated - 24Vdc, max. 0.29 kW; 110/120Vac 60Hz 1Ø, max. 1.34 kVA or 230Vac 60Hz 1Ø, max 1.25 kVA; 230Vac 50Hz 1Ø max. 0.97 kVA; 380-440Vac, 50/60Hz 3Ø, max. 1.66 kVA; 480-575Vac, 60Hz 3Ø, max. 1.66 kVA (with an optional Power Module) or 5.5 kW (with a suitably approved third party motor & hydraulic pump)

Class 1, Zone 1

AEx db eb* IIC T4 Gb IP 66/68**

AEx db eb* IIB T4 Gb IP 66/68**

T amb -40°C* ≤ T_a ≤ +70°C*****

Type 4, Type 6

* “eb” marking only present on versions with increased safety terminal enclosure

** Only IP64 is endorsed by CSA, IP 66/68 testing in accordance with ANSI/IEC 60529:04 (R2011).

*** minimum and maximum values, all values within this range may be quoted within the following limitations:

down to -40°C, up to 70°C (Configuration 1 – IIB & IIC)

down to -40°C, up to 70°C (Configuration 2 – IIB)

down to -20°C, up to 70°C (Configuration 2 – IIC)

Explosionproof for Class I, Division. 1, Groups B, C, D; Temperature Code T4; T amb -40°C ≤ T_a ≤ +70°C

Notes:

1. The above model is permanently connected, Equipment Class I, Pollution Degree 2, Overvoltage Category II.
2. Mode of operation: Isolating (on/off) or Intermittent/duty cycle 300 starts 75% maximum duty up to 40°C; and 300 starts 40% maximum duty from 41°C to 70°C.
3. Environmental Conditions: Normal: 2000 m max, 80% to temperatures up to 31 °C decreasing linearly to 50% rH at 40 °C; or Extended/as specified by manufacturer.

Conditions of Acceptability:

- i. Connection to mains shall be made in accordance with ANSI/NFPA 70, NEC, with CSA C22.1, CEC, Part 1, or both as appropriate.
- ii. To maintain the flameproof and environmental characteristics of the equipment, unused conduit or cable entries must be sealed with suitable blanking elements.
- iii. The temperature of the equipment can reach 81oC at the cable entry and the branching point in a 70oC ambient. This must be considered when selecting field wiring and cable entry devices.
- iv. This equipment shall be installed such that the risk of impact to the window is low.



Certificate: 70005775

Master Contract: 236433

Project: 80197860

Date Issued: May 19, 2025

- v. This equipment includes some external non-metallic parts, including the outer protective coating. The user shall therefore ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a build-up of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.
- vi. The equipment utilises A4-80 fasteners, if these are changed, they shall only be replaced by A4-80 fasteners.
- vii. With reference Clause 5.1 of ANSI/UL 60079-1:2015 and CAN/CSA-C22.2 No. 60079-1:16 - The flamepaths associated with this equipment are not to be repaired.
- viii. Equipment is only to be installed by manufacturer trained personnel.
- ix. If at any time there is a conflict between the system safety provisions and any relevant local (national or regional) requirements, the local requirements always take precedence.
- x. All cover securing fasteners to be tightened to between 20 and 22 Nm during manufacture and following removal for inspection and maintenance purposes.
- xi. The scope of this approval does not include any safety related function, performance or reliability of the equipment.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 61010-1-12, Rev May 11, 2012;
Update No. 1 Rev July 15, 2015; Update No. 2,
Rev April 29, 2016; Amendment 1, Rev
November 16, 2018; Update No. 3, June 6, 2023
CAN/CSA-C22.2 No. 60079-0:19

Safety Requirements for Electrical Equipment for
Measurement, Control, and Laboratory Use — Part 1:
General Requirements

CAN/CSA-C22.2 No. 60079-1:16

Explosive atmospheres — Part 0: Equipment — General
requirements

CAN/CSA-C22.2 No. 60079-7:16

Explosive atmospheres — Part 1: Equipment protection by
flameproof enclosures “d”

CAN/CSA-C22.2 No. 94.2-15

Explosive atmospheres — Part 7: Equipment protection by
increased safety “e”

CSA C22.2 No 30:20

Enclosures for Electrical Equipment, Environmental
Considerations

UL 61010-1 – 3rd Edition, June 6, 2023

Explosion-proof equipment

ANSI/UL-60079-0:2020

Electrical Equipment For Measurement, Control, and
Laboratory Use; Part 1: General Requirements

ANSI/UL 60079-1:2015

Explosive atmospheres – Part 0: Equipment – General
Requirements

ANSI/UL 60079-7:2017

Explosive Atmospheres – Part 1: Equipment Protection by
Flameproof Enclosures “d”

UL 50E (2015)

Explosive atmospheres – Part 7: Equipment protection by
increased safety “e”

FM 3600:2022

Enclosures for Electrical Equipment, Environmental
Considerations

FM 3615:2022

Examination Standard for Electrical Equipment for Use in
Hazardous (Classified)

Examination Standard for Explosionproof Electrical
Equipment – General Requirements



Certificate: 70005775

Project: 80197860

Master Contract: 236433

Date Issued: May 19, 2025

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Marking drawings appear on a minimum 0.02" (0.5mm) thick stainless steel plate, secured to the body with screws, in bottomed holes provided by the enclosure manufacturer.

The following marking details appear on drawing 2040486 (Class/Zones) and 2083386 (Class/Divisions):

- CSA Monogram with c us Indicator (The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only), as shown on the Certificate of Compliance.
- Manufacturer's name "Rotork UK Ltd", or CSA Master Contract number "236433" adjacent the CSA Mark, in lieu of manufacturers name.
- Model designation, as specified in the PRODUCTS section, above.
- Complete electrical rating, as specified in the PRODUCTS section, above.
- Maximum ambient temperature rating, as specified in the PRODUCTS section, above.
- Date code / Serial number traceable to month and year of manufacture.
- Special purpose enclosure designation, "Type 4 and/or Type 6", as specified in the PRODUCTS section, above.
- Ingress Rating as applicable.
- Hazardous locations designation (Class and Zones)
- CAN - "Ex db* IIC T4 Gb" "Ex db* IIB T4 Gb" as specified in the PRODUCTS section, above or equivalent. * "eb" added on versions with increased safety terminal enclosure.
- Hazardous locations designation US - "AEx db* IIC T4 Gb" "AEx db* IIB T4 Gb", as specified in the PRODUCTS section, above or equivalent. * "eb" added on versions with increased safety terminal enclosure.
- Hazardous locations designation (Class and Divisions)
- EXPLOSIONPROOF, CLASS I, DIV 1, GROUPS B, C & D
- Temperature code, as specified in the PRODUCTS section, above.
- The marking: - "SEE CERTIFICATE OR INSTRUCTIONS FOR CONDITIONS OF SAFE USE" and "VOIR CERTIFICAT OU LES INSTRUCTIONS POUR LES CONDITIONS D'UTILISATION SÉCURITAIRE"
- The warning words: "**WARNING! DO NOT OPEN WHILE ENERGISED OR IF AN EXPLOSIVE ATMOSPHERE IS PRESENT**" and "**ATTENTION! NE PAS OUVRIR SOUS TENSION OI SI UNE ATMOSPHERE EXPLOSIVE EST PRESENTE**" or equivalent;



Certificate: 70005775

Master Contract: 236433

Project: 80197860

Date Issued: May 19, 2025

- The warning words: “WARNING! POTENTIAL ELECTROSTATIC CHARGING HAZARD - SEE INSTRUCTIONS” and “ATTENTION” DANGER POTENTIEL DE CHARGE ELECTROSTATIQUE - VOIR LES INSTRUCTIONS” or equivalent;
- The warning words: “WARNING! THE TEMPERATURE AT CABLE ENTRIES MAY REACH 81°C IN SERVICE” and “ATTENTION! LA TEMPERATURE AUX ENTREES DE CABLE PEUT ATTEINDRE 81°C EN SERVICE” or equivalent;
- The warning words: “WARNING! CONDUIT SEALS MUST BE INSTALLED WITHIN 50mm OF THE ENCLOSURE” and “ATTENTION! UN SCELLEMENT DOIT ETRE INSTALLE A MOINS DE 50mm DU BOITIER” or equivalent;
- For **Zones** marked equipment the Certificate Number Reference “CSA 17CA70005775X” next to the CSA logo or preceded by “CSA” agency name.
- For **Divisions** marked equipment the Certificate Number Reference “CERTIFICATE No CSA 70005775” preceded by “CSA” agency name.