

## **Certificate of Compliance**

**AWWA Standard for Rubber-Seated Butterfly Valves C504-10**

**AWWA Standard for Resilient-Seated Cast Iron Eccentric Plug Valves  
C517-09**

### **Manual Valve Actuators**

|                         |                                               |
|-------------------------|-----------------------------------------------|
| Actuator Type:          | IW10                                          |
| Maximum Rated Torque:   | 62390 lbft                                    |
| Ratios:                 | 1080:1 and below                              |
| Maximum handwheel size: | 36 inches, 1080:1; 48 inches, 720:1 and below |

This is to certify that the above-mentioned manual valve actuators are designed and tested to meet or exceed all the requirements of AWWA standard C504-10 and C 517-09.

|                        |                                     |
|------------------------|-------------------------------------|
| Test Report Reference: | T672 and T727                       |
| Design File Reference: | AWWA C504-10 & C517-09, IW10 1080:1 |

Signed:



Steve Watkins  
R&D Engineering Manager

Date of issue: 19<sup>th</sup> October 2011