



Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

PRO. Actuator Setting Tool.

IS/I/1/ABCD/T4 Ta = 50°C

Special Conditions of Use:

1. Only the following batteries shall be used. Duracell Coppertop Type MN1500, Duracell Procell Type MN1500 or GP Super Alkaline Type GP15A.

Equipment Ratings:

Intrinsically Safe for use in Class I, Division 1, Groups A, B, C and D; Temperature Class T4 Ta = 50°C indoor Hazardous (Classified) Locations.

FM Approved for:

Rotork Controls Ltd.
Bath, Avon, BA1 3JQ, United Kingdom