



Certificate no.

TAI-FS-C-25-0027

WE HEREBY CERTIFY THAT

Product description

Pneumatic rack and pinion spring return and double acting actuator

Models

Series GT, RCR

Manufacturer

**Rotork Controls (India) Pvt., Ltd.
RFS division
23/3, Thiruvallur High Road
Thirumazhisai, Chennai, Tamil Nadu 600124
India**

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE
STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE
PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS
THE PRODUCT MEETS ALSO THE REQUIREMENTS OF STANDARD
EN 17955:2024

Assessment report no.

TAI-FS-R-25-0028

Expiry date

03.07.2028

Issue date

23.07.2025

TUV AUSTRIA ITALIA
23.07.2025, Monte Roberto (AN)

Ing. Crescenzo Di Fratta

TUV AUSTRIA ITALIA S.p.A.

Via del Commercio, 6/A 60030 Monte Roberto (AN)
+39 0731 22781 - info@tuvaustraiitalia.com - tuvaustraiitalia@pec.it
C.F./P. IVA IT01055750333 - Cap. Soc. i.v. € 400.000,00 - REA AN n. 211030
Società a socio unico, soggetta a controllo e coordinamento di:
TÜV AUSTRIA HOLDING AG Deutschstrasse 10, A-1230, Vienna, Austria
www.tuvaustraiitalia.com

Annex to certificate no. TAI-FS-C-25-0027

Type	A
HFT	0
Safety functions	<u>Spring return actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
Series GT, RCR (spring return) - No PST	1	2,82E-08	0,00E+00	0,00E+00
Series GT, RCR (spring return) - With PST	1	2,53E-09	2,56E-08	0,00E+00
Series GT, RCR (double acting) - No PST	1	1,20E-08	0,00E+00	0,00E+00
Series GT, RCR (double acting) - With PST	1	1,08E-09	1,09E-08	0,00E+00


Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1H:	Applied	Route 2H:	Applied
	The product can be used in: - single channel configuration: - up to SIL 2 without external diagnostic tests - up to SIL 3 considering external diagnostic tests - double channel configuration: up to SIL 3			

Remarks:

- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM-GT-00-EN

END OF CERTIFICATE

TUV AUSTRIA ITALIA
23.07.2025, Monte Roberto (AN)



Ing. Crescenzo Di Fratta

TUV AUSTRIA ITALIA S.p.A.

Via del Commercio, 6/A 60030 Monte Roberto (AN)
 +39 0731 22781 - info@tuvaustriaitalia.com - tuvaustriaitalia@pec.it
 C.F./P. IVA IT01055750333 - Cap. Soc. i.v. € 400.000,00 - REA AN n. 211030
 Società a socio unico, soggetta a controllo e coordinamento di:
 TÜV AUSTRIA HOLDING AG Deutschstrasse 10, A-1230, Vienna, Austria
 www.tuvaustriaitalia.com